

October 22, 2008

BIO-SYSTEMS INTERNATIONAL
MALCOLM PEACOCK
1238 E. TRUMAN PARKWAY
BELOIT WI 53511

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE
Manufacturer: BIO-SYSTEMS INTERNATIONAL
Product Name: SK3 SEPTIC KLEAN III
Model Number(s): NONE
Product File No: 20080588

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2014.

This approval is contingent upon compliance with the following stipulation(s):

- If the formulation of this approved septic tank additive is modified, or additional assertions of function or performance are made, then this approval shall be rendered null and void, unless the change is submitted to this department for review and the approval reaffirmed.
- This product does not replace the need for a regular program of inspection and maintenance. This includes having the tank pumped out when the volume of sludge and/or scum occupies one-third of the tanks liquid capacity.

This approval supersedes the approval issued on March 23, 2004 under product file number 20030546.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030546.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov